

Serial No.  
**002235**

# MOBILE CATERING VEHICLE/TRAILER SAFETY CHECK

NEXT SAFETY  
CHECK DUE WITHIN  
**6 MONTHS**



This safety check is for gas safety purposes only in accordance with The Gas Safety (Installation and Use) Regulations.

Business Details REGISTRATION NO 195/67  
 Name C MUNDAY (Print name)  
 Tel No. 2343061  
C MUNDAY  
E PARK RD  
KEYSINGHAM BRISTOL  
33135 Tel No. 0117947445

Details of Vehicle  Trailer  tick appropriate box  
 Reg No. or Serial/Chassis No. BURDEN 101101  
 LPG cylinder housing satisfactory Yes/No Y/N  
 Fire extinguisher(s) provided Yes/No Y/N  
 Fire blanket provided Yes/No/NA Y/N  
 Current safety certificate displayed Yes/No N  
 Safe use of LPG information displayed Yes/No N

Vehicle/Trailer Owner Details  
 Name (Mr/Mrs/Miss/Ms) IRAN KNIGHT  
 Address 75 COLTACK AVENUE  
NARBOROUGH, LEICESTER  
 Postcode LE19 4JZ Tel No. 07540539312

No. of appliances tested 6

Appliance type	Make	Model	Serial No.	Flue type OF/PS/FL	Is appliance secure Yes/No	Is appliance isolation valve fitted Yes/No
1 ATM HMTDR	MURCO			C/F	Y/N	Y/N
BULLER				C/F	Y/N	Y/N
BULLER				C/F	Y/N	Y/N
FRYER	IMPURIA			P/F	Y/N	Y/N
FRYER	IMPURIA			P/F	Y/N	Y/N

ating pressure in ar or heat input kW or Btu/h	Safety device(s) correct operation Yes/No/NA	Ventilation provision satisfactory Yes/No/NA	Visual condition of flue satisfactory Yes/No/NA	Flue termination satisfactory Yes/No/NA	Flue flow check Pass/Fail/NA	Spillage check Pass/Fail/NA	Appliance serviced Yes/No	Appliance safe to use Yes/No
6.25	YES	YES	N/A	N/A	N/A	PASS	Y/N	Y/N
6.00	YES	YES	N/A	N/A	N/A	PASS	Y/N	Y/N
4.00	YES	YES	N/A	N/A	N/A	PASS	Y/N	Y/N
5.00	YES	YES	N/A	N/A	N/A	PASS	Y/N	Y/N

Cylinder/final connection hoses to installation satisfactory Yes/No Y/N  
 Gas installation pipework (visual inspection) satisfactory Yes/No Y/N  
 Gas tightness/soundness test satisfactory Yes/No/NA Y/N  
 ECV accessible and operable Yes/No Y/N  
 LPG regulator operating pressure (mbar) 30  
 LPG regulator lock-up pressure (mbar) 30

Safety check issued by: Signed [Signature]  
 Print name: C MUNDAY  
 Received by: [Signature]  
 Date appliance(s)/flue(s) checked: 21.2.11

